



9306-ETS SENSOR

BINMINDER TX/RX BOARD, SEE BINMINDER 9300 INSTALLATION MANUAL, SECTION 6.3.1

JP2 PIN 1(4,7,10 FOR ADDITIONAL SENSORS)  
 JP2 PIN 2(5,8,11 FOR ADDITIONAL SENSORS)  
 JP2 PIN 3(6,9,12 FOR ADDITIONAL SENSORS)

POWER FROM BINMINDER HARNESS  
 POINT #1 TURBIDITY 4-20mA  
 TO CUSTOMER CONTROL SYSTEM.

ETS SENSOR TERMINAL STRIP.  
 MOUNTED INSIDE BINMINDER  
 PROCESSOR ENCLOSURE.

THIS DRAWING IS THE PROPERTY OF  
**ENTECH DESIGN, Inc.**  
 AND IS LOANED UNDER AGREEMENT THAT IT IS NOT TO BE  
 REPRODUCED OR COPIED, IN WHOLE OR IN PART, OR USED  
 FOR ANY OTHER PURPOSE WITHOUT THE WRITTEN CONSENT OF ENTECH  
 DESIGN, INC. ANY UNAUTHORIZED USE OF THIS DRAWING IS  
 PROHIBITED AND WILL BE RETURNED UPON REQUEST.

**Entech Design, Inc.**  
 315 S. LOCUST STREET, TX 75081

SCALE: N/A DRAWN BY: TODD McGLENDON

DATE: 4-12-04

ETS SENSOR  
 CONNECTION DIAGRAM

BINMINDER 9300

DRAWING NO.  
 9306-66-05

1. CORRECTED WIRING I.D. 12-21-04

REVISIONS